



When Hw is 'ON' on clock
and Hw is calling from Cylinder Stat
NC SP/DP contactor will open closing to CH MU
if it was open. On Hw Stat being satisfied contactor
will close re-engaging MU on CH.