

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 1: DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION	
Registration No: <u>011441</u>	Branch No: <u>000</u>	Contractor Reference Number (CRN):	Occupier: <u>100/1 Orlane</u>	UPRN:	Address: <u>100 CASHEL RD COVENTRY</u>
Trading Title: <u>NEVIN ELECTRICS LTD</u>	Name: <u>100/1 Orlane</u>	Address: <u>44 MARLIN Crescent PORTSMOUTH</u>	Address: <u>100 CASHEL RD COVENTRY</u>	Postcode: <u>CV5 5SN</u>	Tel No: <u>01957 346382</u>
Address: <u>100 CASHEL RD COVENTRY</u>	Postcode: <u>CV5 5SN</u>	Tel No: <u>01957 346382</u>	Postcode: <u>CV5 5SN</u>	Tel No: <u>01957 346382</u>	

PART 2: PURPOSE OF THE REPORT

Purpose for which this report is required: Sale of house

Date(s) when inspection and testing was carried out: 13/8/24 Records available (651.1): (.....) Previous inspection report available (651.1): (.....) Previous report date: (.....)

PART 3: SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): EARTHING OFF THE INSTALLATION IS INADEQUATE - WIRES TO SMALL + PENDING TO HIGH. FUSE BOARDS ARE NON COMPLIANT AND NEED TO BE REPLACED

Description of premises Dwelling: (☒) Commercial: (.....) Industrial: (.....) Other (include brief description):

Estimated age of electrical installation: (50) years Evidence of additions or alterations: (☒) if Yes, estimated age 30 years Overall assessment of the installation for continued use: Satisfactory/Unsatisfactory** (delete as appropriate)

**An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.

PART 4: DECLARATION

INSPECTION AND TESTING

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capitals) on behalf of the contractor identified in PART 1: SAM IRON Signature: SAM IRON Date: 13/8/24

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: LYA (date)

Give reason for recommendation: TO MAKE SAFE INSTALLATION HAS BEEN MADE SAFE

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR

Name (capitals) on behalf of the contractor identified in PART 1: SAM IRON Signature: [Signature] Date: 13/8/24

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 5 : OBSERVATIONS

One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action:

Code C1 Danger Present
Risk of injury. Immediate remedial
action required

Code C2 Potentially Dangerous
Urgent remedial action required

Code C3
Improvement Recommended

Code FI
Further Investigation Required

Referring to the **Schedule of Items Inspected** (see PART 9), the attached **Schedule of Circuit Details and Test Results** (see PART 11A & 11B), and subject to any agreed limitations listed in PART 6 –

No remedial action is required (.....), OR The following observations are made:

Item No	Observation(s)	Code	Location Reference
(1..)	MAIN EARTH READING IS TOO HIGH	C3	(.....)
(2..)	FUSE BOARD IN GARAGE IS NOT MADE OF METAL	C3	(.....)
(3..)	NO RCD PROTECTION ON SOCKETS OR SHOWERS	C2	(.....)
(4..)	NO RCD PROTECTION ON CIRCUITS CONCEALED IN THE BUILDING FABRIC	C3	(.....)
(5..)	NO SURGE PROTECTION	C3	(.....)
(6..)	SOCKET IN BATH ROOM NOT WORKING	FI	(.....)
(7..)	SIGNS OF OVERHEATING CABLE AT DB2 FOR SHOWER	C2	(.....)
(8..)	OIL LINE & WATER MAIN ONLY 6MM EARTH NEEDS TO BE 10MM EARTH	C2	(.....)
(9..)	EARTH TO FUSE BOARDS ONLY 10MM SHOULD BE 16MM EARTH	C2	(.....)
(10..)	NO SMOKE-HEAT-CO DETECTION IN HOUSE	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)

Immediate remedial action required for items: (.....)
Urgent remedial action required for items: (1,3,7,8,9)

Additional pages? (.....) State page numbers: (.....)
Improvement recommended for items: (2,4,5)
Further investigation required for items: (6)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 6 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended to 13/1/24 (date). Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the electrical installation covered by this report:

Agreed limitations including the reasons, if any, on the inspection and testing (653.2): LIMITED INSULATION RESISTANCE TESTING NOT PRACTICAL TO REMOVE ALL LAMP & ELECTRONIC EQUIPMENT

Agreed with (print name):

Extent of sampling: (see additional page No.)

Operational limitations including the reasons: (see additional page No.)

PART 7 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements	Number and type of live conductors	Nature of supply parameters	[1] By enquiry [2] By enquiry or by measurement
TN-C: (.....) TN-S: (.....) TN-C-S: (.....) ✓	AC 1-phase, 2-wire: (.....) ✓ 2-phase, 3-wire: (.....) 3-phase, 3-wire: (.....) 3-phase, 4-wire: (.....)	Nominal voltage between lines, U [1]: (230) V	
TT: (.....) IT: (.....)	DC 2-wire: (.....) 3-wire: (.....) Other: (.....)	Nominal line voltage to Earth, U_0 [1]: (230) V	
Supply protective device	Confirmation of supply polarity: (.....) ✓	Nominal frequency, f [1]: (50) Hz	
BS EN: (1361) Type: (T10) Rated current: (100) A	Other sources of supply (Schedule of Test Results) Page No: (.....)	Prospective fault current, I_{pf} [2]*: (48) kA	
		External earth fault loop impedance, Z_e [2]*: (51) Ω	

PART 8 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Maximum demand (load): (.....) kVA/A (delete as appropriate)	Main protective conductors	Main protective bonding connections	Main switch / Switch-fuse / Circuit-breaker / RCD
Means of Earthing	Earthing conductor: (material COPPER) csa (10) mm ² Connection/continuity verified: (.....) ✓	Water installation pipes: (.....) ✓ Gas installation pipes: (.....) Structural steel: (.....) Oil installation pipes: (.....) ✓ Lightning protection: (.....) Other (state): (.....)	Location: (Garage) BS EN: (60947-3) Type: (.....) Rating / setting of device: (100) A No. of poles: (2) Current rating: (100) A Voltage rating: (230) V
Distributor's facility: (.....) ✓	Main protective bonding conductors: (material COPPER) csa (6) mm ² Connection/continuity verified: (.....) ✓		Where an RCD is used as the main switch RCD rated residual operating current, $I_{\Delta n}$: (.....) mA RCD Type: (.....) Rated time delay: (.....) ms Measured operating time: (.....) ms
Installation earth electrode(s): (.....)			
Earth electrode type – rod(s), tape, etc: (.....)			
Location: (.....)			
Electrode resistance to Earth: (.....) Ω			

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists, or Code appropriately: CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 5, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

1.0 Intake equipment (visual inspection only)

An outcome against an item in section 1.1, other than access to live parts, should not be used to determine the overall assessment of the installation. Where inadequacies are identified, a cross should be put against the appropriate item and a comment made in Part 5 of this report.

1.1 Distributor / supplier intake equipment

- Service cable (.....)
- Service head (.....)
- Earthing arrangement (.....)
- Meter tails (.....)
- Metering equipment (.....)
- Isolator, where present (.....)

Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.

- 1.2 Consumer's isolator, where present (.....)
- 1.3 Consumer's meter tails (.....)

2.0 Presence of adequate arrangements for parallel or switched alternative sources

- 2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6) (.....)
- 2.2 Adequate arrangements where a generating set operates in parallel with the public supply (551.7) (.....)

3.0 Methods of protection

- 3.1 Automatic disconnection of supply (ADS)
 - Main earthing / bonding arrangement (411.3; Chap. 54) (.....)
 - Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2), or presence of installation earth electrode arrangement (542.1.2.3) (.....)
 - Adequacy of earthing conductor size (542.3; 543.1.1) (.....)
 - Adequacy of earthing conductor connections (542.3.2) (.....)
 - Accessibility of earthing conductor connections (543.3.2) (.....)
 - Adequacy of main protective bonding conductor sizes (544.1.1) (.....)
 - Adequacy and location of main protective bonding conductor connections (544.1.2) (.....)

- Accessibility of all protective bonding connections (543.3.2) (.....)
- Provision of earthing / bonding labels at all appropriate locations (514.13.1) (.....)
- 3.2 FELV - requirements satisfied (411.7) (.....)
- 3.3 Other methods of protection

Where any of the methods listed below are employed, details should be provided on separate sheets

 - Non-conducting location (418.1) (.....)
 - Earth-free local equipotential bonding (418.2) (.....)
 - Electrical separation (413; 418.3) (.....)
 - Double insulation (412) (.....)
 - Reinforced insulation (412) (.....)
 - Provisions where automatic disconnection of supply is not feasible (419) (.....)

4.0 Distribution equipment, including consumer units and distribution boards

- 4.1 Adequacy of working space / accessibility to equipment (132.12; 513.1) (.....)
- 4.2 Security of fixing (134.1.1) (.....)
- 4.3 Condition of insulation of live parts (416.1) (.....)
- 4.4 Adequacy security of barriers or enclosures (416.2.3) (.....)
- 4.5 Condition of enclosure(s) in terms of IP rating, etc. (416.2) (.....)
- 4.6 Condition of enclosure(s) in terms of fire rating, etc. (421.1.201; 421.1.6; 526.5) (.....)
- 4.7 Enclosure not damaged / deteriorated so as to impair safety (651.2) (.....)
- 4.8 Presence and effectiveness of obstacles (417.2) (.....)
- 4.9 Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2) (.....)
- 4.10 Operation of main switch(es) (functional check) (643.10) (.....)
- 4.11 Manual operation of circuit-breakers, RCDs and AFDDs to prove functionality (643.10) (.....)
- 4.12 Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (643.10) (.....)
- 4.13 RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.4.5; 411.5.2; 531.2) (.....)
- 4.14 RCD(s) provided for additional protection / requirements, where required - includes RCBOs (411.3.3; 415.1) (.....)
- 4.15 Presence of RCD six-monthly test notice, where required (514.12.2) (.....)

- 4.16 Confirmation that integral test button / switch, where present, causes AFDD to trip when operated (643.10) (.....)
- 4.17 Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1) (.....)
- 4.18 Presence of alternative supply warning notice at or near equipment, where required (514.15) (.....)
- 4.19 Presence of next inspection recommendation label, where required (514.12.1) (.....)
- 4.20 Presence of other required labelling (please specify) (514) (.....)
- 4.21 Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (432; 433; 434) (.....)
- 4.22 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3) (.....)
- 4.23 Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11) (.....)
- 4.24 Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1) (.....)
- 4.25 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1) (.....)

5.0 Distribution circuits

- 5.1 Identification of conductors (514.3) (.....)
- 5.2 Cables correctly supported throughout their run (521.10.202; 522.8.5) (.....)
- 5.3 Condition of insulation of live parts (416.1) (.....)
- 5.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) (.....)
- 5.5 Suitability of containment systems for continued use (including flexible conduit) (522) (.....)
- 5.6 Cables correctly terminated in enclosures (526) (.....)
- 5.7 Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (421.1; 522.6) (.....)
- 5.8 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523) (.....)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

5.9 Adequacy of protective devices; type and rated current for fault protection (411.3)	✓	6.2 Cables correctly supported throughout their run (521.10.202; 522.8.5)	(✓)	*For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)	(N/A)
5.10 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(✓)	6.3 Condition of insulation of live parts (416.1)	(✓)	*For final circuits supplying luminaires within domestic (household) premises (411.3.4)	(C3)
5.11 Coordination between conductors and overload protective devices (433.1; 533.2.1)	(✓)	6.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	(✓)		
5.12 Cable installation methods / practices with regard to the type and nature of installation and external influences (522)	(✓)	6.5 Suitability of containment systems for continued use (including flexible conduit) (522)	(✓)		
5.13 Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(✓)	6.6 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (523)	(✓)		
5.14 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –		6.7 Adequacy of protective devices; type and rated current for fault protection (411.3)	✓		
▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	✓	6.8 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	(✓)		
▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(C2)	6.9 Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	(✓)		
5.15 Provision of fire barriers, sealing arrangements and protection against thermal effects (527)	✓	6.10 Wiring system(s) appropriate for the type and nature of the installation and external influences (522)	(✓)		
5.16 Band II cables segregated / separated from Band I cables (528.1)	(✓)	6.11 Where exposed to direct sunlight, cable of a suitable type (522.11.1)	(✓)		
5.17 Cables segregated / separated from non-electrical services (528.3)	(✓)	6.12 Cables concealed under floors, above ceilings, in walls / partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204) –			
5.18 Condition of circuit accessories (651.2)	(✓)	▪ Installed in prescribed zones (see Section D. <i>Extent and limitations</i>) (522.6.202)	(✓)		
5.19 Suitability of circuit accessories for external influences (512.2)	(✓)	▪ Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D) (522.6.201; 522.6.204)	(✓)		
5.20 Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	(✓)	6.13 Provision of additional protection by RCD having rated residual operating current not exceeding 30 mA –			
5.21 Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment - identify / record numbers and locations of items inspected (526)	(C2)	▪ *For all socket-outlets of rating 32 A or less (411.3.3)	(C2)		
5.22 Presence, operation and correct location of appropriate devices for isolation and switching (Chap. 46; 537)	(✓)	Additional protection by RCD may not have been provided as a noted exception in certain non-domestic installations covered by indent (ii) of Regulation 411.3.3.			
5.23 General condition of wiring system (651.2)	(✓)	▪ *For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	(C2)		
5.24 Temperature rating of cable insulation (522.11; Table 52.1)	(✓)	▪ *For cables concealed in walls at a depth of less than 50 mm (522.6.202)	(C2)		
6.0 Final circuits					
6.1 Identification of conductors (514.3)	(✓)				
				7.0 Isolation and switching	
				7.1 Isolators –	
				▪ Presence and condition of appropriate devices (462; 537.2)	(✓)
				▪ Acceptable location - state if local or remote from equipment in question (462; 537.2.7)	(✓)
				▪ Capable of being secured in the OFF position (462.3)	(✓)
				▪ Correct operation verified (643.10)	(✓)
				▪ Clearly identified by position and / or durable marking (537.2.7)	(✓)
				▪ Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	(✓)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 – Requirements for Electrical Installations

PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

7.2	Switching off for mechanical maintenance –	✓	8.5	Security of fixing (134.1.1)	(✓)	▪ Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	(✓)
	▪ Presence and condition of appropriate devices (464.1; 537.3.2)	(✓)	8.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: list number and location of luminaires inspected (separate page) (527.2)	(✓)	▪ Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	(✓)
	▪ Capable of being secured in the OFF position where not under continuous supervision (464.2)	(✓)	8.7	Recessed luminaires (downlighters) –		▪ Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	(✓)
	▪ Correct operation verified (643.10)	(✓)		▪ Correct type of lamps fitted (559.3.1)	(✓)	▪ Suitability of current-using equipment for particular position within the location (701.55)	(✓)
	▪ Clearly identified by position and / or durable marking (537.3.2.4)	(✓)		▪ Installed to minimise build-up of heat by use of “fire rated” fittings, insulation displacement box or similar (421.1.2)	(✓)	9.2	Other special installations or locations –
7.3	Emergency switching off –			▪ No signs of overheating to surrounding building fabric (559.4.1)	(✓)		
	▪ Presence and condition of appropriate devices (465; 537.3.3; 537.4)	(✓)		▪ No signs of overheating to conductors / terminations (526.1)	(✓)		
	▪ Readily accessible for operation where danger might occur (537.3.3.6)	(✓)	9.0	Special locations and installations			
	▪ Correct operation verified (643.10)	(✓)		Where special installations or locations relating to a particular Section of Part 7, an additional Inspection Schedule(s) should be provided on separate pages.			
	▪ Clearly identified by position and / or durable marking (537.3.3.5; 537.3.3.6; 537.4.3; 537.4.4)	(✓)	9.1	Location(s) containing a bath or shower –			
7.4	Functional switching –			▪ Additional protection by RCD having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.411.3.3)	(✓)	10.0	Prosumer's low voltage installation
	▪ Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	(✓)		▪ Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	(✓)		Where elements of a prosuming installation falling within the scope of Chapter 82 are covered by the report, additional schedules detailing the associated inspection and testing should be provided on separate pages.
	▪ Correct operation verified (643.10)	(✓)		▪ Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	(✓)		
8.0	Current-using equipment (permanently connected)			▪ Presence of supplementary bonding conductors, unless not required by BS 7671: 2018 (701.415.2)	(✓)		
8.1	Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4)	(✓)					
8.2	Equipment does not constitute a fire hazard (421)	(✓)					
8.3	Enclosure not damaged / deteriorated so as to impair safety (134.1.1; 416.2)	(✓)					
8.4	Suitability for the environment and external influences (512.2)	(✓)					

PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9.2 above)	Schedules relating to Prosumer's installations (indicated in item 10 above)	Continuation sheets
Page No(s): (4, 5 & 6)	Page No(s): (7 & 8)	Page No(s):	Page No(s):	Page No(s):	Page No(s):

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018+A2:2022* – Requirements for Electrical Installations

PART 11A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

[illegible]

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation:.....

Location of DB:

 Z_{db} : (Ω) I_{pf} at DB⁺: (kA)

Confirmation of supply polarity: (.....) Phase sequence confirmed†: (.....)

SPD Details** Types: T1 (.....) T2 (.....) T3 (.....) N/A (.....)

Status indicator checked (where functionality indicator is present): (.....)

****SPD Type.**

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 11B), (See Section 534 for further details). Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from:

Overcurrent protective device for the distribution circuit

BS (EN): (.....) Type: (.....) Nominal voltage: (.....) V Rating: (.....) A No. of phases: (.....)

Associated RCD (if any)

BS (EN): (.....) RCD Type: (.....) $I_{\Delta n}$: (.....) mA No. of poles: (.....) Operating time: (.....) ms

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with *BS 7671: 2018+A2:2022* – Requirements for Electrical Installations

PART 11B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part 11A)

[illegible]

Circuits/equipment vulnerable to damage when testing (where applicable):

TESTED BY: Name (ospital): SARA HERNANDEZ Position: CLERICAL Signature: [Signature] Date: 12/8/24

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:
-----------------	-------------	------------------------	-----------------------------	-----------------------------	------

* RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	Other (state):
---------------------------------	--	---	---	--	--	---------------------------------------	---------------------------------------	-------------------------------------	----------------------

CONTINUATION SHEET : EIC and EICR

Issued in accordance with *BS 7671: 2018+A2:2022* – Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

[illegible]

DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB2

Location of DB: BACK STONE RM

Z_{db} : -46 (Ω) I_{pf} at DB⁺: -536 (kA)

Confirmation of supply polarity: (.....) Phase sequence confirmed: (.....)

SPD Details** Types: T1 (.....) T2 (.....) T3 (.....) N/A (✓.....)

Status indicator checked (where functionality indicator is present): (.....)

****SPD Type.**

Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.

Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B), (See Section 534 for further details).

Note that not all SPDs have visible functionality indication.

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: main

Overcurrent protective device for the distribution circuit

BS (EN): (.....) Type: (.....) Nominal voltage: (.....) V Rating: (.....) A No. of phases: (.....)

Associated RCD (if any)

BS (EN): (.....) RCD Type: (.....) $I_{\Delta n}$: (.....) mA No. of poles: (.....) Operating time: (.....) ms

PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)

[illegible]

Circuits/equipment vulnerable to damage when testing (where applicable).....

TESTED BY: _____ Name (Capitals): JOHN FLOY Position: LINEBACKER # _____ Date: 1/31/24

TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:

* RCD effectiveness is verified using an alternating current test at rated residual operating current ($I_{\Delta n}$)

** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

For an EIC, enter a (✓) or value in the respective fields, as appropriate.
For an EICR, enter (✓), (X) or value in the respective fields, as appropriate
Where an item is not applicable insert N/A